



Colorado Department  
of Public Health  
and Environment

**Inorganic Chemicals Certified Laboratory Report Form**  
**WQCD - Drinking Water CAS**  
**Submit Online at <http://www.wqcdcompliance.com/login>**

Revised 4/13/2015

**IOC**

Section I (Supplied or Completed by Public Water System)				Section II (Supplied or Completed by Certified Laboratory)				
Public Water System Information				Certified Laboratory Information				
PWSID#: CO0162724				Laboratory ID: CO015				
System Name: St Vrain WTP				Laboratory Name: Colorado Analytical Laboratory				
Contact Person: Wayne Ramey		Phone #: 303-833-5505		Contact Person: Customer Service		Phone: 303-659-2313		
Comments:		Do Samples Need to be Composited BY THE LAB? <input type="checkbox"/>		Comments:				
Section III (Supplied or Completed by Public Water System)								
Sample Date: 7/27/23		Collector: Aaron Evans		Facility ID (On Schedule): 002		Sample Pt ID (On Schedule): 002		
Section IV Inorganic Chemicals (Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
7/27/23	7/27/23	230727078-01	Fluoride	7681-49-4	EPA 300.0	4	0.10	0.67

NT: Not Tested

Lab MRL: Laboratory Minimum Reporting Level

BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter

MCL: Maximum Contaminant Level

8/11/23  
230727078-01  
1/1  
02





Colorado Department  
of Public Health  
and Environment

**Inorganic Chemicals Certified Laboratory Report Form**  
**WQCD - Drinking Water CAS**  
**Submit Online at <http://www.wqcdcompliance.com/login>**

Revised 4/13/2015

**IOC**

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0162724		Laboratory ID: CO015	
System Name: St Vrain WTP		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Wayne Ramey	Phone #: 303-833-5505	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? <input type="checkbox"/>	Comments:	

Section III (Supplied or Completed by Public Water System)			
Sample Date: 7/27/23	Collector: Aaron Evans	Facility ID (On Schedule): 002	Sample Pt ID (On Schedule): 002

Section IV Inorganic Chemicals (Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
7/27/23	8/3/23	230727078-01A	Antimony	7740-36-0	EPA 200.8	0.006	0.001	<b>BDL</b>
7/27/23	8/3/23	230727078-01A	Arsenic	7440-38-2	EPA 200.8	0.01	0.001	<b>BDL</b>
7/27/23	8/3/23	230727078-01A	Barium	7440-39-3	EPA 200.8	2	0.001	<b>0.001</b>
7/27/23	8/3/23	230727078-01A	Beryllium	7440-41-7	EPA 200.8	0.004	0.001	<b>BDL</b>
7/27/23	8/3/23	230727078-01A	Cadmium	7440-43-9	EPA 200.8	0.005	0.001	<b>BDL</b>
7/27/23	8/3/23	230727078-01A	Chromium	7440-47-3	EPA 200.8	0.1	0.001	<b>0.003</b>
7/27/23	8/3/23	230727078-01A	Mercury	7439-97-6	EPA 200.8	0.002	0.0001	<b>BDL</b>
7/27/23	8/3/23	230727078-01A	Nickel	7440-02-0	EPA 200.8	N/A	0.001	<b>0.002</b>
7/27/23	8/3/23	230727078-01A	Selenium	7782-49-2	EPA 200.8	0.05	0.001	<b>BDL</b>
7/27/23	7/31/23	230727078-01A	Sodium	7440-23-5	EPA 200.7	N/A	0.1	<b>3.5</b>
7/27/23	8/3/23	230727078-01A	Thallium	7440-28-0	EPA 200.8	0.002	0.001	<b>BDL</b>

NT: Not Tested  
Lab MRL: Laboratory Minimum Reporting Level  
BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter  
MCL: Maximum Contaminant Level

8/11/23  
230727078-01A  
1/1  
Y





Colorado Department  
of Public Health  
and Environment

**Nitrate and Nitrite as Nitrogen Certified Laboratory Report Form**  
**WQCD - Drinking Water CAS**  
**Submit Online at <http://www.wqcdcompliance.com/login>**

Revised 4/13/2015

**NOX**

Section I (Supplied or Completed by Public Water System)					Section II (Supplied or Completed by Certified Laboratory)							
Public Water System Information					Certified Laboratory Information							
PWSID#: CO0162724					Laboratory ID: CO015							
System Name: St Vrain WTP					Laboratory Name: Colorado Analytical Laboratory							
Contact Person: Wayne Ramey			Phone #: 303-833-5505		Contact Person: Customer Service				Phone: 303-659-2313			
Comments:					Comments:							
Section III (Supplied or Completed by Public Water System)					Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Collector	Facility ID On Schedule	Sample Pt ID On Schedule	Confirmation?	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (mg/L)	Lab MRL (mg/L)	Result (mg/L)
7/27/23	Aaron Evans	002	002	<input type="checkbox"/>	7/27/23	7/27/23	230727078-01	Nitrite Nitrogen	EPA 300.0	1	0.1	<b>BDL</b>
7/27/23	Aaron Evans	002	002	<input type="checkbox"/>	7/27/23	7/27/23	230727078-01	Nitrate Nitrogen	EPA 300.0	10	0.1	<b>0.3</b>

NT: Not Tested  
Lab MRL: Laboratory Minimum Reporting Level  
BDL: Below Laboratory MRL. A less than (<) may also used.

mg/L: Milligrams per Liter  
MCL: Maximum Contaminant Level

8/11/23  
230727078-01  
1/1  
Y

