



## Monthly Operating Report (MOR) Summary Form

Revision: 7/11/2017

Submit Online at [www.wqcdcompliance.com/login](http://www.wqcdcompliance.com/login)  
 Guidance available at [www.colorado.gov/cdphe/swtr](http://www.colorado.gov/cdphe/swtr)

# MOR

Yellow Background = PWS Input Value		Blue Background = Calculated Value		Red Background = Violation	
<b>Public Water System Information Section</b>					
PWS ID:	CO0162724	PWS Name:	ST VRRAIN WATER AUTHORITY	MOR Type:	Membrane
Facility ID:	002	Facility Name:	WATER TREATMENT PLANT	Month:	Jun (6)
		Year:			2023
Contact Person:	R. Wayne Ramey	Email:	wayner@recinc.net	Phone:	303-833-5505
					Save as Final State (xlsx)
Comments:					
<b>Turbidity Combined Filter Effluent (CFE) Summary Section</b>					
<b>*If at ANY time the turbidity rises above 0.5 NTU the PWS must contact the department within 24 hours.</b>					
Facility ID:	002	Required Number of Samples Per Day:			6
Number of Samples Required:	18	Number of Samples Taken:	18	Number of Plant Offs:	162
Number of Days Sampling Required:	30	Number of Days Sampling Met:	30	M&R Complied:	Yes
Number of Samples Exceeding 0.5 NTU:	0	Highest Sample:	0.088	Max TT Complied:	Yes
Number of Samples Exceeding 0.1 NTU:	0	% Samples Exceeding:	0	95% TT Complied:	Yes
<b>Microbial Treatment - Minimum Disinfection Summary Section</b>					
<b>*If at ANY time the residual falls below 0.2 mg/L the PWS must contact the department within 48 hours.</b>					
Facility ID:	002	Required Number of Samples Per Day:			6
Number of Samples Required:	18	Number of Samples Taken:	18	Number of Plant Offs:	162
Number of Days Sampling Required:	30	Number of Days Sampling Met:	30	M&R Complied:	Yes
Number of Samples Below 0.2 mg/L:	0	Lowest Sample:	1.11	Min TT Complied:	Yes
Longest Duration Below Minimum:	N/A (No Values Below Minimum)				

